



# ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.  
75964-0000, TX Nacogdoches  
Phone: 936-569-7941  
Fax: 936-560-4685



## **DPU222RGF20WTST Air Conditioning Disconnect 60A Non-Fused Mettalic** *Eaton Corp*

Catalog Number	DPU222RGF20WTST
Manufacturer	Eaton Corp
Description	Eaton Air Conditioning Disconnect, 60A Non-Fused, Metallic, WRTR, 20A Ground Fault Self-Test
Weight per unit	8.0 (lbs/each)
Product Category	Non-Fusible Disconnect Safety

### **Features**

Material	Galvanized Steel
----------	------------------

### **Material, Color, and Finish**

Color	Gray
-------	------

### **Dimensions and Weight**

Depth	7.5
Height	13
Width	4.75

### **Descriptions**

Description	AIR CONDITIONING DISCONNECT 60A NON-FUSED METTALIC
extra long description	ETN DPU222RGF20WTST AIR COND DISCON
Features	Eaton offers the industry's most complete line of ACDs. Devices are available in fused, non-fused, molded case switch or three phase designs, and in metal or plastic enclosures for all application. An Air Conditioning Disconnect (ACD) provides an installer or repair personnel with a visible disconnecting means while performing maintenance on an air conditioning unit.
Long Description	Eaton air conditioning disconnect, 60A Non-Fused, Metallic, WRTR, 20A ground fault self-test
Product Type	Air Cond Discon, 60A Non-Fused, Metallic

### **Manufacturer Information**

Brand	Eaton
GTIN	00786685982199
Manufacturers Part Number	DPU222RGF20WTST
UPC	786685982199

### **Taxonomies, Classifications, and Categories**

Category Description	A/C DISCONNECTS
Type	Air conditioning disconnect

### **Packaging**

Carton	1
Weight Per each	8



# ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.  
75964-0000, TX Nacogdoches  
Phone: 936-569-7941  
Fax: 936-560-4685

## Uses, Certifications, and Standards

Application

Elec Assemblies, Panels & EOEM - Electrical Assemblies, Panels  
and EOEMs

standard

Contact Manufacturer