

ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685



ST9 3-1/2" Myers Hub *Crouse-Hinds*

Crouse-Hinds	
Catalog Number	ST9
Manufacturer	Crouse-Hinds
Description	Eaton Crouse-Hinds Series Myers Scru-Tite Basic Hub, Zinc, 3-1/2"
Weight per unit	2.9 (lbs/each)
Product Category	Rigid Conduit Fittings - Steel
Features	
connection	Threaded
dimensions	4.9800 IN X 2.5200 IN X 4.9800 IN
Material	Zinc
Material, Color, and Finish	
Finish	Natural
Dimensions and Weight	
Size	3-1/2 in
Descriptions	
Description	3-1/2" MYERS HUB
extra long description	MYERS ST 9 CH MYERS 3 1/2 ZINC COND
Features	Crouse-Hinds series Myers hubs are used in the termination of electrical circuits through wall of an enclosure. They are designed for use indoors or outdoors with rigid conduit and IMC, and they are ideal for pharmaceutical, chemical and food processing, pulp/paper, nuclear, solar and commercial construction applications.
Long Description	Eaton Crouse-Hinds series Myers Scru-Tite basic hub, Zinc, 3-1/2"
Product Type	CH Myers 3 1/2 Zinc Conduit Hub
Special Features	Vibration Proof, Posi-Lok Insulated Throat, Weight 300 Lb per 100
Manufacturer Information	
Brand	Eaton
GTIN	00784731100115
Manufacturers Part Number	ST 9
UPC	784731100115
Taxonomies, Classifications, and (Categories
Category Description	Watertight Hub, 3-PIECE COUPLINGS, THREADLESS COUPLINGS

Taxo

Type	Basic hub
Tuno	Pocio hub
	AND THREADLESS CONNECTOR
Category Description	Watertight Hub, 3-PIECE COUPLINGS, THREADLESS COUPLINGS

Packaging

Carton	2	
Weight Per each	2.9	

ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685

Uses, Certifications, and Standards

Application	Commercial / Institutional Buildings / Structures - Commercial /
	Institutional Buildings / Structures - Other
Enclosure	NEMA 2/3/3R/4/4X/12
standard	UL 514B, CUL, CSA C22.2