



Catalog Number: UC7636-YL-TGE-DES  
Item Description: 20A 6T RT TS07-0105 PRWRD  
UPC Code: 784572145788

Brand Name: Milbank  
Type: Ringless Meter Socket  
Application: Meter Socket  
Standard: UL Listed  
Voltage Rating: 600 Volts Alternating Current  
Amperage Rating: 20 Continuous Ampere  
Phase: 1 Phase  
Frequency Rating: 60 Hertz  
Number Of Cutouts: 0  
Cable Entry: Overhead and Underground  
Terminal: Single Mechanical Line Side and Single Mechanical Load Side  
Mounting: Surface Mount  
Enclosure: Type 3R, G90 Galvanized Steel with Powder Coat Finish



Additional Specifications: Number of Jaws:6 Terminal  
Hub Opening and Closing Plates:1 1/4 Inch Hub  
Hub Opening and Closing Plates:1 1/4 Inch Hub  
Hub Opening and Closing Plates:1 1/4 Inch Hub  
Hub Opening and Closing Plates:1 1/4 Inch Hub  
Hub Opening and Closing Plates:1 1/4 Inch Hub

*Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.*



Catalog Number: UC7636-YL-TGE-DES  
Item Description: 20A 6T RT TS07-0105 PRWRD  
UPC Code: 784572145788

Brand Name: Milbank  
Type: Ringless Meter Socket  
Application: Meter Socket  
Standard: UL Listed  
Voltage Rating: 600 Volts Alternating Current  
Amperage Rating: 20 Continuous Ampere  
Phase: 1 Phase  
Frequency Rating: 60 Hertz  
Number Of Cutouts: 0  
Cable Entry: Overhead and Underground  
Terminal: Single Mechanical Line Side and Single Mechanical Load Side  
Mounting: Surface Mount  
Enclosure: Type 3R, G90 Galvanized Steel with Powder Coat Finish



Additional Specifications: Number of Jaws:6 Terminal  
Hub Opening and Closing Plates:1 1/4 Inch Hub  
Hub Opening and Closing Plates:1 1/4 Inch Hub  
Hub Opening and Closing Plates:1 1/4 Inch Hub  
Hub Opening and Closing Plates:1 1/4 Inch Hub  
Hub Opening and Closing Plates:1 1/4 Inch Hub

*Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.*