

# ELLIOTT ELECTRIC SUPPLY 2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685





## WS2000l Occ/Vac Sensor, Pir, 120/277V, Iv Hubbell Wiring Devices

Catalog Number	WS2000I
Manufacturer	Hubbell Wiring Devices
Description	Lighting Controls, Occupancy/Vacancy Sensors, Wall Switch,
	Passive Infrared Technology, 120/277V Ac, Ivory
Weight per unit	0.2500 (lbs/each)
Product Category	Lighting Occupancy Sensors

#### **Features**

connector	Screwed Terminal
load	Lighting Circuit
pallet quantity	1350
supply voltage	120/277 AC
Voltage Rating	120/277

#### **Dimensions and Weight**

C' .	115' 100' 1/0'
\$1 <b>7</b> ↑	// I
Size	4.15 in x 1.82 in x 1.62 in
VILU	

#### **Descriptions**

Description	OCC/VAC SENSOR,PIR,120/277V,IV
extra long description	HWDK WS2000I OCC/VAC SENSOR,PIR,120
Features	Standard Passive Infrared Technology requires a clear, unobstructed line of sight for detection, because it senses occupancy as movement of heat emitted from the body against the background space. A segmented Fresnel lens divides a coverage area into zones. Movement across zones is interpreted as occupancy. Excellent for small room control.
Long Description	Lighting Controls, Occupancy/Vacancy Sensors, Wall Switch, Passive Infrared Technology, 120/277V AC, Ivory
Product Type	Occ/Vac Sensor, Pir, 120/277V, Iv
Special Features	Standard Product

#### **Manufacturer Information**

Brand	WIRING DEVICE-KELLEMS
GTIN	00783585256306
Manufacturers Part Number	WS2000I
series	Passive Infrared
UPC	783585256306

### Taxonomies, Classifications, and Categories

Category Description	Residential dimmers, motion sensors, controls, & photo cells
Туре	Manual/Auto



## ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685

U	2	$\boldsymbol{\sim}$	v	2	a		n	$\sim$
г	a	b	N	а	u	ı		u
					J			J

Carton	1
Package	10
Weight Per each	0.25

#### Uses, Certifications, and Standards

Application	Compatible with most LED and CFL
environmental conditions	Indoor Dry unless protected by additional means
Mounting	Mounting Screws
standard	cULus Listed To UL773A