



# ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.  
75964-0000, TX Nacogdoches  
Phone: 936-569-7941  
Fax: 936-560-4685



## XJG108SA 4" Expansion Joint

*Crouse-Hinds*

Catalog Number	XJG108SA
Manufacturer	Crouse-Hinds
Description	Eaton Crouse-Hinds Series XJG Expansion Coupling, Rigid/Imc, Copper-Free Aluminum, 8" Maximum Conduit Movement, 4" Trade Size
Weight per unit	10.6 (lbs/each)
Product Category	Aluminum

### Features

dimensions	13.8100 IN X 6.6200 IN X 6.6200 IN
Material	Copper Free Aluminum

### Descriptions

Description	4" EXPANSION JOINT
extra long description	CRS-H XJG108 SA 4 AL CND EXP JNT IN
Features	"XJG conduit expansion couplings for EMT and rigid/IMC are used with EMT, rigid metal conduit and IMC to couple together two sections of conduit subject to longitudinal movement. They are installed indoors or outdoors in long conduit runs to permit linear movement caused by thermal expansion and contraction to prevent damage to conduit supports and electrical systems in building or bridges. XJGs for rigid/IMC and EMT are also available with a hot dip galvanized finish (standard for trade sizes 1-1/4" and
Long Description	Eaton Crouse-Hinds series XJG expansion coupling, Rigid/IMC, Copper-free aluminum, 8" maximum conduit movement, 4" trade size
Product Type	4 Al CND Exp JNT Int GRD Max CNDT MVT 8

### Manufacturer Information

Brand	Eaton
GTIN	00782274916095
Manufacturers Part Number	XJG108 SA
UPC	782274916095

### Taxonomies, Classifications, and Categories

Category Description	PVC SPACERS
Type	Expansion coupling

### Packaging

Carton	1
Weight Per each	10.55



# ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.  
75964-0000, TX Nacogdoches  
Phone: 936-569-7941  
Fax: 936-560-4685

## Uses, Certifications, and Standards

Application	Commercial / Institutional Buildings / Structures - Commercial / Institutional Buildings / Structures - Other
Enclosure standard	NEMA FB1 UL 514B, CSA C22.2